




REMMING



ZAVRŠNA KONTROLA ZAPISNIK O ISPITIVANJU EKONOMAJZERA VRELOVODNOG KOTLA		Dokument br.: 2332 - ZIP - 002
Vrsta kontrola:	Hladnim vodenim pritiskom: 36.4 bar(g)	
Investitor:	JKP "Novosadska toplana" Novi Sad	
Proizvođač:	REMMING D.O.O.	
Ugovor br.:	2332/17	
DETALJI:	PARAMETRI ISPITIVANJA:	
Fabrički broj: 825	Ispitni medijum:	Voda
Crtež br.: 825-00-00.00	Ispitni pritisak:	36.4 bar
Materijal: Prema listi materijala	Temp. ispitnog medijuma:	20 °C
Maksimalni radni pritisak: 12 bar	Vreme održanja na ispitnom pritisku:	30 min
Radna temperatura: 150°C	Vrsta ispitivanja:	Ispitivanje pritiskom u radionici
Manometar proizvođača / vrsta / serijski broj / opseg: FADIP / Ø160 / 3953 / 0-60 bar		
Zaključak: Tokom izvedenog ispitivanja na pritisak nisu zabeležene deformacije na materijalu ili curenje ispitnog medijuma.		
Rukovodilac proizvodnje:	Kontrola kvaliteta:	
 Dragan Đurić	 Dušan Jokić, struk. ing. maš.	
Datum: 02.07.2018. Mesto: Beočin		

REMMING D.O.O.

List Ferenc 2
21480 Srbobran
Serbia
PIB: SR101425093

OFFICE: REMMING - Novi Sad
Branislava Nušića 15, SRB-21000 Novi Sad
Tel: +381-(0)21-548-151
Fax: +381-(0)21-47-39-120
E-mail: info@remming.co.rs
Internet: www.remming.co.rs