



REMMING



ISO 9001:2008



ISO 14001:2004

www.tuv.com
ID: 9105028479www.tuv.com
ID: 9105028479

ZAVRŠNA KONTROLA ZAPISNIK O ISPITIVANJU UTILIZATORA		Dokument br.: 2332 - ZIP - 003	
Vrsta kontrola:	Hladnim vodenim pritiskom: 36.4 bar(g)		
Investitor:	JKP "Novosadska toplana" Novi Sad		
Proizvođač:	REMMING D.O.O.		
Ugovor br.:	2332/17		
DETALJI:		PARAMETRI ISPITIVANJA:	
Fabrički broj: 826		Ispitni medijum: Voda	
Crtež br.: 826-00-00.00		Ispitni pritisak: 36.4 bar	
Materijal: Prema listi materijala		Temp. ispitnog medijuma: 20 °C	
Maksimalni radni pritisak: 12 bar		Vreme održanja na ispitnom pritisku: 30 min	
Radna temperatura: 70°C		Vrsta ispitivanja: Ispitivanje pritiskom u radionici	
Manometar proizvođača / vrsta / serijski broj / opseg: FADIP / Ø160 / 000586 / 0-60 bar			
Zaključak: Tokom izvedenog ispitivanja na pritisak nisu zabeležene deformacije na materijalu ili curenje ispitnog medijuma.			
Rukovodilac proizvodnje:		Kontrola kvaliteta:	
 _____ Dragan Đurić		 _____ Dušan Jokić, struk. ing. maš.	
Datum: 02.07.2018. Mesto: Beočin			



REMMING D.O.O.
List Ferenc 2
21480 Srbobran
Serbia
PIB: SR101425093

OFFICE: REMMING - Novi Sad
Branislava Nušića 15, SRB-21000 Novi Sad
Tel.: +381-(0)21-548-151
Fax: +381-(0)21-47-39-120
E-mail: info@remming.co.rs
Internet: www.remming.co.rs